



Qualifying Equipment for Tax Credits

Credits Limited to 30% of Installed Costs (up to \$1,500) in the tax years 2009 and 2010.

Equipment

Electric Air Source Heat Pumps

Minimum Energy Efficiency Standard to Qualify

Split Heat Pumps

Package Heat Pumps

15 SEER

14 SEER

12.5 EER

12 EER

8.5 HSPF

8 HSPF

Central Air Conditioners

Split System

Package System

16 SEER

14 SEER

13 EER

12 EER

Geothermal Heat Pump

(30% of total installation eligible, no dollar cap*)

Closed Loop

Open Loop

Direct Expansion

14.1 EER

16.2 EER

15 EER

3.3 COP

3.6 COP

3.5 COP

*Solar electric, solar hot water, and wind also eligible, including new construction

Natural Gas Furnace

95% AFUE

Natural Gas Hot Water Boiler

90% AFUE

Propane Furnace

95% AFUE

Propane Hot Water Boiler

90% AFUE

Oil Furnace

90% AFUE

Oil Hot Water Boiler

90% AFUE

Gas, Oil or Propane Water Heaters

.82 Energy Factor

90% Thermal Efficiency

Electric Heat Pump Hot Water Heater

2.0 Energy Factor

Wood Stoves

75% Thermal

Efficiency as measured using a lower heating value.

Advanced Main Cir Circulating Fan (ECMs)

No more than 2% of furnace total energy use